

Inspection Field Sheet

Building Sewer

Use this check sheet when inspecting a building sewer. After the inspection attach it to the local agency copy of the sewage permit and keep as a record of the inspection.

Property Location: _____

Inspection Date: _____ SEO: _____

- Cleanouts found to be acceptable.
 - Cleanout inside the structure Cleanout is outside
 - Cleanouts are no more than 100 feet (if applicable)
- Building sewer is constructed of durable material suitable to handle the weight of backfilling and meeting any local codes.
- Building sewer is _____ inches in diameter. (3 inches minimum for flows of less than 1000 g.p.d. 6 inches if greater.)
- Building sewer has no joint of greater than 45°
- Building sewer is pitched downward from the structure to the tank with the last 10 feet pitched between 1/8 and 1/4 inch to the foot.
- Building sewer allows continuous venting of gases.
- Building sewer has water tight joints and the tank entry is sealed with
 - hydraulic grout or a mechanical seal.

Signed _____