



PASEO | 4902 Carlisle Pike #268 | Mechanicsburg PA 17050 | www.PA-SEO.org

Field Chart for Determining the Minimum Septic Tank Size Based on the Number of Bedrooms

Number of Bedrooms Gallons of Septic Tank Capacity Required

3	900
4	1250
5	1400
6	1550
7	1700
8	1850
9	2000